Your service provider

SR-2026-0142

Preventive maintenance report

2026-11-03

Customer
Sample customer

Technician
Alex Tremblay

Site
Montreal - Data centre, Montréal

Visit date
2026-11-03 09:00

1. Units serviced

UNIT	SERIAL NUMBER	LOCATION	CONDITION
APC Smart-UPS SRT 6000	AS2231170842	Server room 2	Good

Condition class (NFPA 70B) at this visit, based on the technician's status

APC Smart-UPS SRT 6000 · AS2231170842 · Class 1 · good condition

2. Work performed

APC Smart-UPS SRT 6000 · AS2231170842 · Server room 2

General checks

✓ Visual inspection

3. Readings

APC Smart-UPS SRT 6000 · AS2231170842 · Server room 2

Input voltage (V)	**120**	Output voltage (V)	**120**
Load (%)	**42**	Battery voltage (V)	**218.4**
Battery temperature (°C)	**23**	Runtime (min)	**31**

4. Observations

APC Smart-UPS SRT 6000 · AS2231170842 · Server room 2

Batteries within specification. Fans and filters cleaned. Self-test passed.

5. Visit summary

Annual preventive maintenance completed. The UPS and its batteries are in good condition.